



LAB REPORT

Report Number	(9325)210-1284
Date of sampling	31/07/2025
Reporting Date	06/08/2025

Audit ID	30050	Audit firm	Bureau Veritas –GUANGZHOU
Company name	FUJIAN COLORFUL CITY DIGITAL TECHNOLOGY CO.,LTD		
Contact person	Shengkang Min		
Type of tax - tax ID no	91350582MA344UGF4P		
Address	Yinglin Industrial Park, Yinglin Town, Jinjiang, Quanzhou		
Region state province	FUJIAN		
Town city / village	YINGLIN		
Zip/Post code	362200		

Type of wastewater discharge			
Type of waste discharge	Indirect Discharge without Pre-treatment		
Description of the discharge	Discharge to Jinjiang City Sanrong Yinhua Zhizao Co., Ltd.		
Ambient temperature of receiving water body (direct discharge only)	Not Applicable		
Type of treatment			
PRELIMINARY	PRIMARY	SECONDARY / BIOLOGICAL	TERTIARY
<input type="checkbox"/> Screening/Sieving/Grit remover	<input type="checkbox"/> Coagulation/Flocculation	<input type="checkbox"/> Activated sludge process/Aerobic reactor	<input type="checkbox"/> Absorption with activated carbon
<input type="checkbox"/> Homogenization tank	<input type="checkbox"/> Dissolved air flotation (DAF)	<input type="checkbox"/> Biological Biofilm reactor (MBBR, SAF, RBC...)	<input type="checkbox"/> High rate filtration
<input type="checkbox"/> pH correction	<input type="checkbox"/> Sedimentation tanks or Settler/Clarifier	<input type="checkbox"/> Sequencing batch reactor (SBR)	<input type="checkbox"/> Techniques (ozonation, Fenton reaction, photo catalytic degradation...)
<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Other

Bureau Veritas Consumer Products Services
(Guangzhou) Co., Ltd
No. 183, Shinan Road, Meilin Plaza, Dongchong,
Nansha, Guangzhou, Guangdong Province, China
511453
Tel: (86) 20 2290 2088 Fax: (86) 20 3490 9303
Email: BVCPs_pyinfo@cn.bureauveritas.com
Website: cps.bureauveritas.com

This report is governed by, and incorporates by reference, the Conditions of Testing as posted at the date of issuance of this report at <http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions/> and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. Statements of conformity are based on simple acceptance criteria without taking measurement uncertainty into account, unless otherwise requested in writing. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.

Sampler accreditation certification number (ZDHC):		C74D106817263	
Sample description			
	Simple	Composite	Comments
(1) Wastewater before treatment	NO	YES, Black, composite sample at 10:30, 11:30, 12:30, 13:30, 14:30, 15:30, 16:30	/
(2) Wastewater after treatment	NO	NO	/
(3) Sludge	NO	NO	/

Local Legal Data	
Local Legal Standard name [a]	Not Applicable
Parameters (ZDHC WWG V2.2, Table 2 & 3) exceeded local regulation:	Not Applicable
Discharge permit provided	NO
Discharge flow data	≥15 m ³ /day

Internal description – Final Test Report	
Internal codification number	(9325)210-1284
Reference sample number	I001: Wastewater before treatment
Received on	02/08/2025
Analysis carried out from	02/08/2025 to 06/08/2025
Arrival Temperature at Lab	6.8 °C
Comments	Samples received within maximum holding time
Reporting date	06/08/2025
Date and time of the beginning of sampling	31/07/2025, 10:30
Date and time of the end of sampling	31/07/2025, 16:30
Sample holding time exceeded	NO



Report Number

(9325)210-1284

If there are questions or concerns on this report, please contact the following persons:

General enquiry and invoicing

(86)20-22902088

bvcps_pyinfo@bureauveritas.com

Technical enquiry-Chemical

(86)20-22902088

bvcps_pyinfo@bureauveritas.com

This report shown the test result of the auxiliary chemical and/or raw material samples, which collected during particular factory audit. The results of this report shall not be used for any regulatory compliance purposes. The sampling is agreed with client.

BUREAU VERITAS CONSUMER PRODUCTS SERVICES (GUANGZHOU) CO., LTD

Reviewed by:

Approved by:

Andy Wang
Manager

Nina Ren
Analytical lab Senior Manager



Summary of test results				
Test items	Sample 1 (Before treatment)	Sample 2 (After treatment)	Sample 3 (Sludge)	Sample 4 (Leachate)
Alkylphenols (APs) & Alkylphenol ethoxylates (APEOs)	ND	NA	NA	NA
Anti-Microbials & Biocides	ND	NA	NA	NA
Chlorinated Paraffins	ND	NA	NA	NA
Chlorobenzenes & Chlorotoluenes	ND	NA	NA	NA
Chlorophenols	ND	NA	NA	NA
N,N-di-methylformamide (DMFa)	ND	NA	NA	NA
Dyes – Carcinogenic or Equivalent Concern	ND	NA	NA	NA
Dyes – Disperse (Allergenic)	ND	NA	NA	NA
Dyes – Navy Blue Colourant	NA	NA	NA	NA
Flame retardants	ND	NA	NA	NA
Glycols	ND	NA	NA	NA
Halogenated Solvents	ND	NA	NA	NA
Organotin compounds	ND	NA	NA	NA
Other / Miscellaneous Chemicals	ND	NA	NA	NA
Perfluorinated and Polyfluorinated Chemicals (PFCs)	ND	NA	NA	NA
Phthalates	ND	NA	NA	NA
Polycyclic Aromatic Hydrocarbons (PAHs)	ND	NA	NA	NA
Restricted Aromatic Amines (Cleavable from Azo-colourants)	ND	NA	NA	NA
UV Absorbers	ND	NA	NA	NA
Volatile Organic Compounds (VOCs)	ND	NA	NA	NA
Heavy metals	Fulfill aspirational limit	NA	NA	NA
Global effluent parameters ZDHC	NA	NA	NA	NA

Remark (Indicated in each parameter)

- | | | | | | |
|-----|---|--|-----|---|-------------------------------|
| ND | = | Not detected (below reporting limit) | NA | = | Not applicable |
| D | = | Detected (equal or above reporting limit) | - | = | Did not perform |
| * | = | See remark | (f) | = | Parameter tested in field |
| @ | = | Maximum holding time exceeded,
Red flag in the ZDHC Gateway – Wastewater Module.
Probable error in results due to the holding time. | (T) | = | Handling temperature exceeded |
| # | = | Non accredited parameter | | | |
| (S) | = | Analysis was subcontracted for testing | | | |
| [a] | = | The local legal standard name and legal standard number is referenced to discharge permit (or contractual agree by CETP) that provided by company. | | | |



Test results

1. Alkylphenols (APs) & Alkylphenol Ethoxylates (APEOs)

ISO 18857-2, ASTM D7065

Alkylphenols (APs) & Alkylphenol ethoxylates (APEOs)	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Nonylphenoethoxylates (NPEOs)	Multiple including 9016-45-9/ 26027-38-3/ 37205-87-1/ 68412-54-4/ 127087-87-0	5	5	ND	µg/L
Nonylphenol (NP)	Multiple including 104-40-5/ 11066-49-2/ 25154-52-3/ 84852-15-3	5	5	ND	µg/L
Octylphenoethoxylates (OPEOs)	Multiple including 9002-93-1/ 9036-19-5/ 68987-90-6	5	5	ND	µg/L
Octylphenol (OP)	Multiple including 140-66-9/ 1806-26-4/ 27193-28-8	5	5	ND	µg/L

2. Anti-Microbials & Biocides

EPA 3510C:1996, EPA 8270E:2018

Anti-Microbials & Biocides	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
o-Phenylphenol (+salts)	90-43-7	100	Sample and report only	ND	µg/L
Triclosan	3380-34-5	100	100	ND	µg/L
Permethrin	Multiple including 52645-53-1	500	500	ND	µg/L

3. Chlorinated Paraffins

EPA 3510C:1996, ISO 18219-2:2021, ISO 12010:2019

Chlorinated Paraffins	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Medium-chain chlorinated paraffins (MCCPs) (C14-C17)	85535-85-9	500	500	ND	µg/L
Short-chain chlorinated paraffins (SCCPs) (C10'-C13)	85535-84-8	25	25	ND	µg/L



Report Number

(9325)210-1284

4. Chlorobenzenes & Chlorotoluenes

EPA 8270E:2018

Chlorobenzenes & Chlorotoluenes	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
1,2-dichlorobenzene	95-50-1	0.2	0.2	ND	µg/L
Other isomers of mono-, di-, tri-, tetra-, penta-, and hexa- chlorobenzene and mono-, di-, tri-, tetra-, and penta-chlorotoluene	Multiple including 108-90-7/ 541-73-1/ 106-46-7/ 87-61-6/ 120-82-1/ 108-70-3/ 634-66-2/ 634-90-2/ 95-94-3/ 608-93-5/ 118-74-1/ 95-49-8/ 108-41-8/ 106-43-4/ 32768-54-0/ 95-73-8/ 19398-61-9/ 118-69-4/ 95-75-0/ 25186-47-4/ 7359-72-0/ 2077-46-5/ 6639-30-1/ 23749-65-7/ 21472-86-6/ 1006-32-2/ 875-40-1/ 1006-31-1/ 877-11-2	0.2	0.2	ND	µg/L

5. Chlorophenols

USEPA 8270E, BS EN 12673-1999

Chlorophenols	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
2-Chlorophenol	95-57-8	0.5	0.5	ND	µg/L
2,3-Dichlorophenol	576-24-9	0.5	0.5	ND	µg/L
2,3,4-Trichlorophenol	15950-66-0	0.5	0.5	ND	µg/L
2,3,5-Trichlorophenol	933-78-8	0.5	0.5	ND	µg/L
2,3,6-Trichlorophenol	933-75-5	0.5	0.5	ND	µg/L
2,4-dichlorophenol	120-83-2	0.5	0.5	ND	µg/L
2,4,5-Trichlorophenol	95-95-4	0.5	0.5	ND	µg/L
2,4,6-Trichlorophenol	88-06-2	0.5	0.5	ND	µg/L
2,5-Dichlorophenol	583-78-8	0.5	0.5	ND	µg/L
2,6-Dichlorophenol	87-65-0	0.5	0.5	ND	µg/L
3-Chlorophenol	108-43-0	0.5	0.5	ND	µg/L
3,4-Dichlorophenol	95-77-2	0.5	0.5	ND	µg/L
3,4,5-Trichlorophenol	609-19-8	0.5	0.5	ND	µg/L
3,5-Dichlorophenol	591-35-5	0.5	0.5	ND	µg/L
4-Chlorophenol	106-48-9	0.5	0.5	ND	µg/L
Pentachlorophenol (PCP)	87-86-5	0.5	0.5	ND	µg/L
2,3,5,6-Tetrachlorophenol	935-95-5	0.5	0.5	ND	µg/L
2,3,4,6-Tetrachlorophenol	58-90-2	0.5	0.5	ND	µg/L
2,3,4,5-Tetrachlorophenol	4901-51-3	0.5	0.5	ND	µg/L



Report Number

(9325)210-1284

6. N,N-di-methylformamide (DMFa)

EPA 8015, EPA 8270E:2018

DMFa	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Dimethyl formamide; N,N-dimethylformamide (DMFa)	68-12-2	1000	Sample and report	ND	µg/L

7. Dyes – Carcinogenic or Equivalent Concern

EPA 8321B:2007

Carcinogenic dyes	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Basic violet 3 with >0.1% of Michler's Ketone	548-62-9	500	500	ND	µg/L
C.I. Acid Red 26	3761-53-3	500	500	ND	µg/L
C.I. Acid Violet 49	1694-09-3	500	500	ND	µg/L
C.I. Basic Blue 26 (with Michler's Ketone > 0.1%)	2580-56-5	500	500	ND	µg/L
C.I. Basic Green 4 (malachite green chloride)	569-64-2	500	500	ND	µg/L
C.I. Basic Green 4 (malachite green oxalate)	2437-29-8	500	500	ND	µg/L
C.I. Basic Green 4 (malachite green)	10309-95-2	500	500	ND	µg/L
C.I. Basic Red 9	569-61-9	500	500	ND	µg/L
C.I. Basic Violet 14	632-99-5	500	500	ND	µg/L
C.I. Direct Black 38	1937-37-7	500	500	ND	µg/L
C.I. Direct Blue 6	2602-46-2	500	500	ND	µg/L
C.I. Direct Red 28	573-58-0	500	500	ND	µg/L
C.I. Disperse Blue 1	2475-45-8	500	500	ND	µg/L
C.I. Disperse Blue 3	2475-46-9	500	500	ND	µg/L
C.I. Disperse Orange 11	82-28-0	500	500	ND	µg/L

8. Dyes – Disperse (Allergenic)

EPA 8321B:2007

Disperse dyes	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Disperse Blue 102	12222-97-8	50	NA	ND	µg/L
Disperse Blue 106	12223-01-7	50	NA	ND	µg/L
Disperse Blue 124	61951-51-7	50	NA	ND	µg/L
Disperse Blue 26	3860-63-7	50	NA	ND	µg/L
Disperse Blue 35	12222-75-2	50	NA	ND	µg/L



Report Number

(9325)210-1284

Disperse Blue 35	56524-77-7	50	NA	ND	µg/L
Disperse Blue 7	3179-90-6	50	NA	ND	µg/L
Disperse Brown 1	23355-64-8	50	NA	ND	µg/L
Disperse Orange 1	2581-69-3	50	NA	ND	µg/L
Disperse Orange 3	730-40-5	50	NA	ND	µg/L
Disperse Orange 37/59/76	13301-61-6	50	NA	ND	µg/L
Disperse Red 1	2872-52-8	50	NA	ND	µg/L
Disperse Red 11	2872-48-2	50	NA	ND	µg/L
Disperse Red 17	3179-89-3	50	NA	ND	µg/L
Disperse Yellow 1	119-15-3	50	NA	ND	µg/L
Disperse Yellow 3	2832-40-8	50	NA	ND	µg/L
Disperse Yellow 39	12236-29-2	50	NA	ND	µg/L
Disperse Yellow 49	54824-37-2	50	NA	ND	µg/L
Disperse Yellow 9	6373-73-5	50	NA	ND	µg/L

9. Dyes – Navy Blue Colourant

EPA 8321B:2007

Dyes – Navy Blue Colourant	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Component 1: C39H23Cl-CrN7O12S 2Na	118685-33-9	NA	NA	NA	µg/L
Component 2: C46H-30CrN10O20S2 3Na	Not allocated	NA	NA	NA	µg/L

10. Flame retardants

USEPA 8270, ISO 22032, USEPA 527 and USEPA 8321B, EPA 3015A:2007, EPA 6020B:2014

Flame retardants	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Boric acid	10043-35-3/ 11113-50-1	500	500	ND	µg/L
Diboron trioxide	1303-86-2	500	500	ND	µg/L
Disodium octaborate	12008-41-2	500	500	ND	µg/L
Disodium tetraborate anhydrous	1303-96-4/ 1330-43-4	500	500	ND	µg/L
Tetraboron disodium heptaoxide, hydrate	12267-73-1	500	500	ND	µg/L
Hexabromocyclododecane (HBCDD)	3194-55-6	25	25	ND	µg/L
2,2-Bis(bromomethyl)-1,3-propanediol (BBMP)	3296-90-0	25	25	ND	µg/L
Polybromobiphenyls (PBBs)	59536-65-1	25	25	ND	µg/L
Monobromobiphenyls (MonoBB)	Multiple	25	25	ND	µg/L
Monobromodiphenylethers (MonoBDEs)	Multiple	25	25	ND	µg/L
Dibromobiphenyls (DiBB)	Multiple	25	25	ND	µg/L
Dibromopropylether	21850-44-2	25	25	ND	µg/L



Report Number

(9325)210-1284

Tribromodiphenylethers (TriBDEs)	Multiple	25	25	ND	µg/L
Tetrabromodiphenyl ether (TetraBDE)	40088-47-9	25	25	ND	µg/L
Pentabromodiphenyl ether (PentaBDE)	32534-81-9	25	25	ND	µg/L
Hexabromodiphenyl ether (HexaBDE)	36483-60-0	25	25	ND	µg/L
Heptabromodiphenyl ether (HeptaBDE)	68928-80-3	25	25	ND	µg/L
Octabromobiphenyls (OctaBB)	Multiple	25	25	ND	µg/L
Octabromodiphenyl ether (OctaBDE)	32536-52-0	25	25	ND	µg/L
Nonabromobiphenyls (NonaBB)	Multiple	25	25	ND	µg/L
Nonabromodiphenyl ether (NonaBDE)	63936-56-1	25	25	ND	µg/L
Decabromobiphenyl (DecaBB)	13654-09-6	25	25	ND	µg/L
Decabromodiphenyl ether (DecaBDE)	1163-19-5	25	25	ND	µg/L
Tetrabromobisphenol A (TBBPA)	79-94-7	25	25	ND	µg/L
Bis(2,3-dibromopropyl) phosphate (BDBPP)	5412-25-9	25	25	ND	µg/L
Tris-(2-chloro-1-methylethyl) phosphate (TCPP)	13674-84-5	25	25	ND	µg/L
Tris(1-aziridinyl) phosphine oxide (TEPA)	545-55-1	25	25	ND	µg/L
Tris(1,3-dichloro-isopropyl) phosphate (TDCP)	13674-87-8	25	25	ND	µg/L
Tris(2-chloroethyl) phosphate (TCEP)	115-96-8	25	25	ND	µg/L
Tris(2,3-dibromopropyl) phosphate (TRIS)	126-72-7	25	25	ND	µg/L

11. Glycols

EPA 8270E:2018

Glycols	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
2-ethoxyethanol	110-80-5	50	50	ND	µg/L
2-ethoxyethyl acetate	111-15-9	50	50	ND	µg/L
2-methoxyethanol	109-86-4	50	50	ND	µg/L
2-methoxyethylacetate	110-49-6	50	50	ND	µg/L
2-methoxypropylacetate	70657-70-4	50	50	ND	µg/L
Bis(2-methoxyethyl)-ether	111-96-6	50	50	ND	µg/L
Ethylene glycol dimethyl ether	110-71-4	50	50	ND	µg/L
Triethylene glycol dimethyl ether	112-49-2	50	50	ND	µg/L



12. Halogenated Solvents

EPA 8260D:2018

Chlorinated solvents	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
1,2-Dichloroethane	107-06-2	1	1	ND	µg/L
Methylene chloride	75-09-2	1	1	ND	µg/L
Trichloroethene	79-01-6	1	1	ND	µg/L
Tetrachloroethene	127-18-4	1	1	ND	µg/L

13. Organotin compounds

ISO 17353

Organotin compounds	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Dipropyltin compounds (DPT)	Multiple including 867-36-7	0.01	0.01	ND	µg/L
Mono-, di-and tri-butyltin derivatives	Multiple including 1118-46-3/ 1461-22-9	0.01	0.01	ND	µg/L
Mono-, di-and tri-methyltin derivatives	Multiple including 993-16-8/ 753-73-1/ 1066-45-1	0.01	0.01	ND	µg/L
Mono-, di-and tri-octyltin derivatives	Multiple including 3091-25-6/ 3542-36-7/ 2587-76-0	0.01	0.01	ND	µg/L
Mono-, di-and tri-phenyltin derivatives	Multiple including 1124-19-2/ 1135-99-5/ 639-58-7	0.01	0.01	ND	µg/L
Tetraethyltin compounds (TeET)	Multiple including 597-64-8	0.01	0.01	ND	µg/L
Tetraoctyltin compounds (TeOT)	Multiple including 3590-84-9	0.01	0.01	ND	µg/L
Tricyclohexyltin (TCyHT)	Multiple including 3091-32-5	0.01	0.01	ND	µg/L
Tripropyltin compounds (TPT)	Multiple including 2279-76-7	0.01	0.01	ND	µg/L

14. Other /Miscellaneous Chemicals

EPA 3510C:1996, EPA 8321B:2007

Other /Miscellaneous Chemicals	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
AEEA [2-(2-aminoethylamino)ethanol]	111-41-1	500	500	ND	µg/L
Bisphenol A	80-05-7	10	10	ND	µg/L
Borate – borate, zinc salt	12767-90-7	100	100	ND	µg/L
Zinc salt – borate, zinc salt		100	100	ND	µg/L
Quinoline	91-22-5	50	50	ND	µg/L
Silica (particles of respirable size)	14464-46-1	NA	NA	NA	µg/L
Thiourea	62-56-6	50	50	ND	µg/L



15. Perfluorinated chemicals (PFCs)

EPA 537:2020, FTOH: BS EN 12673-1999, EPA 8270, PFCs: LC-MSMS, FTOH: GC-MS derivatisation with acetic

Perfluorinated chemicals (PFCs)	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Perfluorooctane sulfonate (PFOS) and related substances	Multiple including 1763-23-1	0.01	0.01	ND	µg/L
Perfluorooctanoic acid (PFOA) and related substances	Multiple including 335-67-1	1	1	ND	µg/L

16. Phthalates – Including all other esters of ortho-phthalic acid

USEPA 8270E, ISO 18856, EPA 3510C:1996, EPA 8270E:2018

Phthalates	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
1,2-benzenedicarboxylic acid, di-C6-11-branched alkyl esters, C7-rich (DIHP)	71888-89-6/ 84777-06-0	10	10	ND	µg/L
1,2-benzenedicarboxylic acid, di-C7-11-branched and linear alkyl esters (DHNUUP)	68515-42-4/ 68515-50-4	10	10	ND	µg/L
Bis(2-methoxyethyl) phthalate (DMEP)	117-82-8	10	10	ND	µg/L
Butyl benzyl phthalate (BBP)	85-68-7	10	10	ND	µg/L
Di-cyclohexyl phthalate (DCHP)	84-61-7	10	10	ND	µg/L
Di-iso-decyl phthalate (DIDP)	26761-40-0	10	10	ND	µg/L
Di-iso-octyl phthalate (DIOP)	27554-26-3	10	10	ND	µg/L
Di-iso-butyl phthalate (DIBP)	84-69-5	10	10	ND	µg/L
Di-iso-nonyl phthalate (DINP)	28553-12-0	10	10	ND	µg/L
Di-n-hexyl phthalate (DnHP)	84-75-3	10	10	ND	µg/L
Di-n-octyl phthalate (DNOP)	117-84-0	10	10	ND	µg/L
Di-n-pentylphthalates	131-18-0	10	10	ND	µg/L
Di-n-propyl phthalate (DPRP)	131-16-8	10	10	ND	µg/L
Di-2-ethylhexyl phthalate (DEHP)	117-81-7	10	10	ND	µg/L
Dibutyl phthalate (DBP)	84-74-2	10	10	ND	µg/L
Diethyl phthalate (DEP)	84-66-2	10	10	ND	µg/L
Diisopentylphthalates	605-50-5	10	10	ND	µg/L
Dinonyl phthalate (DNP)	84-76-4	10	10	ND	µg/L



17. Polycyclic aromatic hydrocarbons (PAHs)

USEPA 8270E DIN 38407-39

PAHs	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Acenaphthene	83-32-9	1	1	ND	µg/L
Acenaphthylene	208-96-8	1	1	ND	µg/L
Anthracene	120-12-7	1	1	ND	µg/L
Benzo(a)anthracene	56-55-3	1	1	ND	µg/L
Benzo(a)pyrene (BaP)	50-32-8	1	1	ND	µg/L
Benzo(b)fluoranthene	205-99-2	1	1	ND	µg/L
Benzo(e)pyrene	192-97-2	1	1	ND	µg/L
Benzo(ghi)perylene	191-24-2	1	1	ND	µg/L
Benzo(j)fluoranthene	205-82-3	1	1	ND	µg/L
Benzo(k)fluoranthene	207-08-09	1	1	ND	µg/L
Chrysene	218-01-9	1	1	ND	µg/L
Dibenz(a,h)anthracene	53-70-3	1	1	ND	µg/L
Fluoranthene	206-44-0	1	1	ND	µg/L
Fluorene	86-73-7	1	1	ND	µg/L
Indeno (1,2,3-cd)pyrene	193-39-5	1	1	ND	µg/L
Naphthalene	91-20-3	1	1	ND	µg/L
Phenanthrene	85-01-8	1	1	ND	µg/L
Pyrene	129-00-0	1	1	ND	µg/L

18. Restricted Aromatic Amines (Cleavable from Azo-colourants)

EPA 3510C:1996 , EPA 8270E:2018

Azo Dyes	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
2-Naphthylamine	91-59-8	0.1	0.1	ND	µg/L
2-Naphthylammoniumacetate	553-00-4	0.1	0.1	ND	µg/L
2,4-Xylidine	95-68-1	0.1	0.1	ND	µg/L
2,4,5-Trimethylaniline	137-17-7	0.1	0.1	ND	µg/L
2,4,5-trimethylaniline hydrochloride	21436-97-5	0.1	0.1	ND	µg/L
2,6-Xylidine	87-62-7	0.1	0.1	ND	µg/L
3,3'-Dichlorobenzidine	91-94-1	0.1	0.1	ND	µg/L
3,3-Dimethoxybenzidine	119-90-4	0.1	0.1	ND	µg/L
3,3-Dimethylbenzidine	119-93-7	0.1	0.1	ND	µg/L
4-Aminoazobenzene	60-09-3	0.1	0.1	ND	µg/L
4-Aminobiphenyl	92-67-1	0.1	0.1	ND	µg/L



Report Number

(9325)210-1284

4-Chloro-o-toluidine	95-69-2	0.1	0.1	ND	µg/L
4-chloro-o-toluidinium chloride	3165-93-3	0.1	0.1	ND	µg/L
4-Chloroaniline	106-47-8	0.1	0.1	ND	µg/L
4-methoxy-m-phenylene diammonium sulphate; 2,4-diaminoanisoole sulphate	39156-41-7	0.1	0.1	ND	µg/L
4-methoxy-m-phenylenediamine	615-05-4	0.1	0.1	ND	µg/L
4-Methyl-m-phenylenediamine	95-80-7	0.1	0.1	ND	µg/L
4,4-Methylene-bis-(2-chloro-aniline)	101-14-4	0.1	0.1	ND	µg/L
4,4-methylenedi-o-toluidine	838-88-0	0.1	0.1	ND	µg/L
4,4-methylenedianiline	101-77-9	0.1	0.1	ND	µg/L
4,4-Oxydianiline	101-80-4	0.1	0.1	ND	µg/L
4,4-Thiodianiline	139-65-1	0.1	0.1	ND	µg/L
5-Nitro-o-toluidine	99-55-8	0.1	0.1	ND	µg/L
6-methoxy-m-toluidine	120-71-8	0.1	0.1	ND	µg/L
Benzidine	92-87-5	0.1	0.1	ND	µg/L
o-Aminoazotoluene	97-56-3	0.1	0.1	ND	µg/L
o-Anisidine	90-04-0	0.1	0.1	ND	µg/L
o-Toluidine	95-53-4	0.1	0.1	ND	µg/L

19. UV Absorbers

EPA 3510C:1996 , EPA 8270E:2018

UV Absorbers	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
2-(2H-benzotriazol-2-yl)-4-(tert-butyl)-6-(sec-butyl) phenol (UV-350)	36437-37-3	100	100	ND	µg/L
2-(2H-benzotriazol-2-yl)-4,6-ditertpentylphenol (UV-328)	25973-55-1	100	100	ND	µg/L
2-benzotriazol-2-yl-4,6-di-tertbutylphenol (UV-320)	3846-71-7	100	100	ND	µg/L
2,4-Di-tert-butyl-6-(5-chlorobenzotriazole-2-yl) phenol (UV-327)	3864-99-1	100	100	ND	µg/L



Report Number

(9325)210-1284

20. Volatile organic compounds (VOCs)

EPA 8260D:2018

VOCs	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 1 (Before treatment)	Unit
Benzene	71-43-2	1	1	ND	µg/L
m-cresol	108-39-4	1	1	ND	µg/L
o-cresol	95-48-7	1	1	ND	µg/L
p-cresol	106-44-5	1	1	ND	µg/L
Toluene	108-88-3	1	1	ND	µg/L
Xylene	1330-20-7	1	1	ND	µg/L



Report Number

(9325)210-1284

21. Heavy metals

EPA 3015A:2007, EPA 6020B:2014, ISO 11885:2007, GB/T 7467-1987

Heavy metals	CAS no.	TEXTILES Limit			LEATHER Limit			Reporting limit & LOQ	Result Sample 1 (before Treatment)	Unit
		F	P	A	F	P	A			
Antimony (Sb)	Various	0.1	0.05	0.01	0.1	0.05	0.01	0.01	NA	mg/L
Chromium VI (Cr VI)	Various	0.05	0.005	0.001	0.15	0.05	0.02	0.001	ND	mg/L
Barium (Ba)	Various	Sample and report only			Sample and report only			1	NA	mg/L
Selenium (Se)	Various	Sample and report only			Sample and report only			1	NA	mg/L
Tin (Sn)	Various	Sample and report only			Sample and report only			1	NA	mg/L
Arsenic (As)	Various	0.05	0.01	0.005	0.05	0.01	0.005	0.005	ND	mg/L
Total Chromium (Cr)	Various	0.2	0.1	0.05	1.5	0.8	0.3	0.05	NA	mg/L
Cobalt (Co)	Various	0.05	0.02	0.01	0.05	0.02	0.01	0.01	NA	mg/L
Cadmium (Cd)	Various	0.1	0.05	0.01	0.1	0.05	0.01	0.01	ND	mg/L
Copper (Cu)	Various	1	0.5	0.25	1	0.5	0.25	0.25	NA	mg/L
Lead (Pb)	Various	0.1	0.05	0.01	0.1	0.05	0.01	0.01	ND	mg/L
Nickel (Ni)	Various	0.2	0.1	0.05	0.2	0.1	0.05	0.05	NA	mg/L
Silver (Ag)	Various	0.1	0.05	0.005	0.1	0.05	0.005	0.005	NA	mg/L
Zinc (Zn)	Various	5.0	1.0	0.5	5	1	0.5	0.5	NA	mg/L
Mercury (Hg)	Various	0.01	0.005	0.001	0.01	0.005	0.001	0.001	ND	mg/L

22. Global effluent parameters

Parameters	Test Method	TEXTILES Limit			LEATHER Limit			Reporting limit & LOQ	Result Sample X (XXXXX Treatment)	Unit
		F	P	A	F	P	A			
pH	HJ 1147-2020	6-9			6-9			NA	NA	pH
Temperature difference	GB/T 13195-1991	Δ+15	Δ+10	Δ+5	Δ+15	Δ+10	Δ+5	NA	NA	°C
E.coli	SM 9221B, SM 9221F	126			126			126	NA	MPN/100ml
Colour (436nm; 525nm; 620nm)	ISO 7887-B:2011	7;5;3	5;3;2	2;1;1	7;5;3	5;3;2	2;1;1	0.1,0.1,0.1	NA	m ⁻¹
Foam	Visual	Not visible			Not visible			NA	NA	/
Wastewater Flowrate	-	15m ³ per day			15m ³ per day			NA	NA	m ³ /day
Ammonium-N	HJ 535-2009	10	1	0.5	15	10	1	0.5	NA	mg/L
AOX	HJ/T 83-2001	3	0.5	0.1	3	0.5	0.1	0.1	NA	mg/L
BOD ₅	HJ 505-2009	30	15	8	50	30	20	0.5	NA	mg/L
COD	HJ 828-2017	150	80	40	250	150	100	4	NA	mg/L
DO	HJ 506-2009	≥4			≥4			NA	NA	mg/L
Oil and grease	HJ 637-2018	10	2	0.5	20	10	5	0.5	NA	mg/L
Phenol	HJ 503-2009	0.5	0.01	0.001	0.5	0.3	0.1	0.001	NA	mg/L
Total Chlorine	HJ 585-2010, HJ 586-2010	1			1			0.04	NA	mg/L
TDS	GB/T 5750.4-2006	Sample and report only			Sample and report only			N/A	NA	mg/L
Total-N	HJ 636-2012	20	10	5	35	20	10	5	NA	mg/L
Total-P	GB/T 11893-1989	3	0.5	0.1	3	1	0.5	0.1	NA	mg/L
TSS	GB/T 11901-1989	50	15	5	70	50	20	5	NA	mg/L
Chloride	HJ 84-2016	Sample and report only			Sample and report only			0.007	NA	mg/L
Cyanide, total	HJ 484-2009	0.2	0.1	0.05	NA	NA	NA	0.05	NA	mg/L
Sulphate	HJ 84-2016	Sample and report only			Sample and report only			0.018	NA	mg/L
Sulphide	HJ 1226-2021	0.5	0.05	0.01	1	0.5	0.2	0.01	NA	mg/L
Sulphite	HJ 84-2016	2	0.5	0.2	2	0.5	0.2	0.2	NA	mg/L



23. Sludge Parameters – Step 1 – MRSL –APs and APEOs: including all isomers (Sludge Disposal Pathway =Not applicable

ISO 18857-2, ASTM D7065, ISO 18254-1, EPA 3540C:1996, EPA 8321B:2007

Sludge Parameters – APs and APEOs	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 3 (Sludge)	Unit
Nonylphenoethoxylates (NPEOs)	Multiple including 9016-45-9/ 26027-38-3/ 37205-87-1/ 68412-54-4/ 127087-87-0	0.4	0.4	NA	mg/kg
Nonylphenol (NP)	Multiple including 104-40-5/ 11066-49-2/ 25154-52-3/ 84852-15-3	0.4	0.4	NA	mg/kg
Octylphenoethoxylates (OPEOs)	Multiple including 9002-93-1/ 9036-19-5/ 68987-90-6	0.4	0.4	NA	mg/kg
Octylphenol (OP)	Multiple including 140-66-9/ 1806-26-4/ 27193-28-8	0.4	0.4	NA	mg/kg

24. Sludge Parameters – Step 1 – MRSL – Polycyclic Aromatic Hydrocarbons (PAHs)

USEPA 3540/3541, USEPA 3550, USEPA 3640, USEPA 827, EPA 3540C:1996, EPA 8270E:2018

PAHs	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 3 (Sludge)	Unit
Acenaphthene	83-32-9	0.2	0.2	NA	mg/kg
Acenaphthylene	208-96-8	0.2	0.2	NA	mg/kg
Anthracene	120-12-7	0.2	0.2	NA	mg/kg
Benzo(a)anthracene	56-55-3	0.2	0.2	NA	mg/kg
Benzo(a)pyrene (BaP)	50-32-8	0.2	0.2	NA	mg/kg
Benzo(b)fluoranthene	205-99-2	0.2	0.2	NA	mg/kg
Benzo(e)pyrene	192-97-2	0.2	0.2	NA	mg/kg
Benzo(ghi)perylene	191-24-2	0.2	0.2	NA	mg/kg
Benzo(j)fluoranthene	205-82-3	0.2	0.2	NA	mg/kg
Benzo(k)fluoranthene	207-08-09	0.2	0.2	NA	mg/kg
Chrysene	218-01-9	0.2	0.2	NA	mg/kg
Dibenz(a,h)anthracene	53-70-3	0.2	0.2	NA	mg/kg
Fluoranthene	206-44-0	0.2	0.2	NA	mg/kg
Fluorene	86-73-7	0.2	0.2	NA	mg/kg
Indeno (1,2,3-cd)pyrene	193-39-5	0.2	0.2	NA	mg/kg
Naphthalene	91-20-3	0.2	0.2	NA	mg/kg
Phenanthrene	85-01-8	0.2	0.2	NA	mg/kg
Pyrene	129-00-0	0.2	0.2	NA	mg/kg



Report Number

(9325)210-1284

25. Sludge Parameters – Step 1 – MRSL – Chlorotoluenes

USEPA 3540/3541, USEPA 3550, USEPA 3640, USEPA 827, EPA 3540C:1996, EPA 8270E:2018

Chlorotoluenes	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 3 (Sludge)	Unit
Other isomers of mono-, di-, tri-, tetra-, and penta- chlorotoluene	Multiple including 95-49-8/ 108-41-8/ 106-43-4/ 32768-54-0/ 95-73-8/ 19398-61-9/ 118-69-4/ 95-75-0/ 25186-47-4/ 7359-72-0/ 2077-46-5/ 6639-30-1/ 23749-65-7/ 1006-32-2/ 875-40-1/ 877-11-2	0.2	0.2	NA	µg/L

26. Sludge Parameters – Step 1 – Metals

EPA 3050, EPA 6020B, USEPA 3060a, USEPA 7196

Sludge Parameters - Metals	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Threshold Values	Result Sample 3 (Sludge)	Unit
Antimony	-	5	NA	12	NA	mg/kg
Arsenic	-	5	2	10	NA	mg/kg
Barium	-	200	NA	700	NA	mg/kg
Cadmium	-	1	2	3	NA	mg/kg
Cobalt	-	400	NA	1600	NA	mg/kg
Copper	-	50	NA	200	NA	mg/kg
Lead	-	5	2	10	NA	mg/kg
Nickel	-	20	NA	70	NA	mg/kg
Selenium	-	5	NA	10	NA	mg/kg
Silver	-	50	NA	100	NA	mg/kg
Zinc	-	400	NA	1000	NA	mg/kg
Total Chromium	-	50	NA	100	NA	mg/kg
Chromium (VI)	-	20	2	50	NA	mg/kg
Mercury	-	1	0.2	1	NA	mg/kg

27. Sludge Parameters – Step 1 – Conventional Parameters & Anions

HJ 962-2018, HJ 613-2011, EPA 1681, EPA 9095B, HJ 745-2015

Sludge Parameters – Conventional & Anions	CAS no.	Reporting limit & LOQ TEXTILE	Reporting limit & LOQ LEATHER	Result Sample 3 (Sludge)	Unit
pH	-	-	-	NA	pH
Fecal Coliform	-	-	-	NA	MPN/g
% Solids	-	-	-	NA	%
Paint Filter Test	-	-	-	NA	-
Cyanide	-	-	-	NA	mg/kg



28. Sludge Parameters – Step 2 – Metals

EPA1311-1992 extraction, EPA 3015A:2007, EPA 6020B:2014, ISO 11885:2007, GB/T 7467-1987

Sludge Parameters – Step 2 - Metals	CAS no.	LOQ	Reporting limit	Result Sample 4 (Leachate)	Unit
Antimony	-	Xxx	-	NA	mg/L
Arsenic	-	Xxx	-	NA	mg/L
Barium	-	Xxx	-	NA	mg/L
Cadmium	-	Xxx	-	NA	mg/L
Cobalt	-	Xxx	-	NA	mg/L
Copper	-	Xxx	-	NA	mg/L
Lead	-	Xxx	-	NA	mg/L
Nickel	-	Xxx	-	NA	mg/L
Selenium	-	Xxx	-	NA	mg/L
Silver	-	Xxx	-	NA	mg/L
Zinc	-	Xxx	-	NA	mg/L
Total Chromium	-	Xxx	-	NA	mg/L
Chromium (VI)	-	Xxx	-	NA	mg/L
Mercury	-	Xxx	-	NA	mg/L

Remark


- | | |
|--|-------------------------------------|
| ND = Not detected (below reporting limit) | NA = Not applicable |
| D = Detected (equal or above reporting limit) | - = Did not perform |
| * = See remark | (f) = Parameter tested in field |
| @ = Maximum holding time exceeded,
Red flag in the ZDHC Gateway – Wastewater Module.
Probable error in results due to the holding time. | (T) = Handling temperature exceeded |
| # = Non accredited parameter | F = Foundational level |
| (S) = Analysis was subcontracted for testing | P = Progressive level |
| [a] = The local legal standard name and legal standard number is referenced to discharge permit (or contractual agree by CETP) that provided by company. | A = Aspirational level |

Annex A: Sampling photos & Sampling locations

Sample 1 – Sampling Point
31/07/2025, 10:33



Sample 1 – Photo of Sample
31/07/2025, 16:46





BUREAU VERITAS

Report Number

(9325)210-1284

Annex B: On-site Field Data Record Sheet

	ZDHC Wastewater Sampling Field Data Form and Representative Sample Declaration	CPSD-AN-00613-DATA 07
		Issue Date: February 20, 2024
		Version No.: 1
		Business Line: Analytical

Attach the completed field data form in the test report.

Facility Information		
Date of Sampling:	31/7/2025	
Sample Number (ZDHC Composite Sample Code):	93252101284	
Facility Name:	福建省彩都数码科技有限公司	
Facility Address:	福建泉州市晋江市英林镇高湖村无幸路35号	
Facility Type (tick all applicable):	<input checked="" type="checkbox"/> Dyeing and Finishing <input type="checkbox"/> Fabric Mill <input type="checkbox"/> Laundry, Washing and Finishing <input type="checkbox"/> Natural Leather processing <input type="checkbox"/> Printing <input type="checkbox"/> Synthetic Leather processing <input type="checkbox"/> Other (please specify)	
Discharge Type (tick applicable):	<input type="checkbox"/> Direct discharge <input type="checkbox"/> with pre-treatment <input checked="" type="checkbox"/> Indirect discharge <input checked="" type="checkbox"/> without pre-treatment <input type="checkbox"/> Zero liquid discharge (ZLD) <input type="checkbox"/> with own ETP	Other Notes:
Discharge Description:	<input type="checkbox"/> Discharge to environment (e.g. river, stream, sea etc.) <input type="checkbox"/> Other (please specify) <input checked="" type="checkbox"/> Sewage treatment plant	
Discharge Volume:	<input checked="" type="checkbox"/> ≥ 15m ³ per day <input type="checkbox"/> < 15m ³ per day To: 晋江市三荣印花织造有限公司 日排: 1000 m ³ /d Addr: 晋江市高湖工业区	

Sample Type and Details	
Sample Type	Sample Details
<input type="checkbox"/> Incoming Water	---
<input checked="" type="checkbox"/> Untreated WW	<input type="checkbox"/> with equalisation tank (EQT) present Hydraulic Retention Time (HRT) (Hours): _____ <small>= volume of tank (m³) / flow rate (m³/h) if HRT > 12 h, grab sampling from EQT is allowed.</small>
<input type="checkbox"/> Effluent	<input type="checkbox"/> Direct <input type="checkbox"/> Indirect <small>Enter sampling time(s) in page 2 and take field test measurements.</small> <small>Enter sampling time(s) in page 2. No field test measurements required except on client's request.</small> <input type="checkbox"/> Facility has WWTP <input type="checkbox"/> Plant is in operating condition <input type="checkbox"/> with equalisation tank (EQT) present Hydraulic Retention Time (HRT) (Hours): _____ <small>= volume of tank (m³) / flow rate (m³/h) if HRT > 12 h, grab sampling from EQT is allowed.</small>
<input type="checkbox"/> Sludge	Disposal Pathway (The pathway must be defined by the facility. If the facility cannot provide information, pathway 'F' shall be assumed.) <input type="checkbox"/> A >1000°C offsite incineration <input type="checkbox"/> B Landfill with significant control <input type="checkbox"/> C Building products processed >1000°C <input type="checkbox"/> D Landfill with limited control <input type="checkbox"/> E Incineration/ Building products processed <1000°C <input type="checkbox"/> F Landfill with no control <input type="checkbox"/> G Land application Sludge flux (weight/time) if applicable: _____

ZDHC Wastewater Sampling Facility Confirmation	
The wastewater samples have been collected under the facilities' normal production scale and wastewater flow rate. The sampler listed below was on-site and collected the samples. Sampling protocol for wastewater and sludge samples are in accordance with ZDHC SAP including appendix E. In no circumstances shall samples be taken during times when the production process is not running or the wastewater is diluted, for example due to heavy rainfall.	
Facility Confirmation	Sampler Information
Facility Name: 福建省彩都数码科技有限公司	Sampler's Name/ Email: 黄模昂
Facility Representative Name: 陈建康	Sampler's ZDHC Accredited No.: 074D10881263
Facility Representative Signature and Stamp:	Sampler's Signature: 黄模昂
Date: 2025.7.31	Date: 31/07/2025



BUREAU
VERITAS

Report Number

(9325)210-1284

Annex B: On-site Field Data Record Sheet (continue)

Measurement (cm)		Meter	Pipe (O)	Flume (U)	Wier (V)
Diameter		--			
Depth		--	--	--	

Parameter	Lab Control Sample (LCS) Known	Lab Control Sample (LCS) Measured	Accuracy (%)
pH			
Total Chlorine			

Incoming Sample Point		<input type="radio"/> Composite Sample <input type="radio"/> Grab Sample		Start Time:	Stop Time:				
Sampling Locations:		GPS coordinates:		Lat.: N / S	Long.: E / W				
Sampling Mode:		<input type="radio"/> Manual <input type="radio"/> Autosampler - Sampling Device Description/ Owner:							
Sampling Time (Hours)		0	1	2	3	4	5	6	Average
Recording time of discrete sample									--
Colour (visual estimation):									

Untreated Sample Point		<input type="radio"/> Composite Sample <input type="radio"/> Grab Sample		Start Time:	Stop Time:				
Sampling Locations:		GPS coordinates:		Lat.: N / S	Long.: E / W				
Sampling Mode:		<input checked="" type="radio"/> Manual <input type="radio"/> Autosampler - Sampling Device Description/ Owner:							
Sampling Time (Hours)		0	1	2	3	4	5	6	Average
Recording time of discrete sample		10:40	11:30	12:30	13:30	14:30	15:30	16:30	--
Colour (visual estimation):		Black	Black	Black	Black	Black	Black	Black	Black

Effluent Sample Point		<input type="radio"/> Composite Sample <input type="radio"/> Grab Sample		Start Time:	Stop Time:				
Sampling Locations:		GPS coordinates:		Lat.: N / S	Long.: E / W				
Sampling Mode:		<input type="radio"/> Manual <input type="radio"/> Autosampler - Sampling Device Description/ Owner:							
Sampling Time (Hours)		0	1	2	3	4	5	6	Average
Recording time of discrete sample									--
Temperature (°C):	WW Discharge								
	Receiving Water								
pH:									
Dissolved Oxygen (mg/L):									
Total Chlorine (mg/L):									
Persistent Foam (Yes/No):		Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No
Wastewater Flow Meter (L/min):									
Alternate Measured Flow:	Depth (cm)								
	Velocity (cm/sec)								
Colour (visual estimation):									
Volume collected (L):									
Total volume collected (L):		Collect 3.33-litres each hour for a total minimum volume of 20-litres							

Sludge Sample Point		<input type="radio"/> Composite Sample <input type="radio"/> Grab Sample		Start Time:	Stop Time:				
Sampling Locations:		GPS coordinates:		Lat.: N / S	Long.: E / W				
Sampling Mode:		<input type="radio"/> Manual <input type="radio"/> Autosampler - Sampling Device Description/ Owner:							
Sampling Time (Hours)		0	1	2	3	4	5	6	Average
Recording time of discrete sample									--
Colour (visual estimation):									

Comments/ Other Observations									



Report Number **(9325)210-1284**

Annex C: Limit according to regulation / Contract limit with centralized ETP (if proceed)

Not Applicable
